

# BATHROOM ZONING

**ZONE 0:** Is the area inside the bath or shower. A minimum rating of IP67 is required (protected against immersion in water) and only SELV (max 12V) fittings may be used.

**ZONE 1:** Is the area directly above the bath or shower tray and to a height of 2.25m. A minimum rating of IP65 is required.

**ZONE 2:** Is the area over the bath tub or shower tray above the sides of Zone 1 up to a distance of 60cm. This is the area external to Zone 1 and extends vertically 0.6m to height of 3m. An IP rating of IP64 is required

**ZONE 3:** Is the area external to Zones 0, 1 & 2, to a distance of 2.4m from Zone 2 and a height above the floor of 3m. The protection required for luminaries in this zone for normal domestic use is IP20

**NOTE:** The above are guidelines only. Where water jets are being used for cleaning, a minimum of IP65 applies

